



GENERAL NOTES

- A) CEILING HEIGHT BUILD OUT AREA TO BE 10' & CEILING TO BE FLOOR RATED
- B) BUILDING 20' HEIGHT, INSIDE DOORWAY
- C) SPRINKLER SYSTEM REQUIRED AND BURGLAR ALARM READY
- D) NATURAL LIGHT SHOULD BE USED IN WAREHOUSE
- E) TWO ROOF EXHAUST FANS IN WAREHOUSE AREA
- F) WEARHOUSE FLOOR CONCRETE W/ CONC. SEALER
- G) OFFICES, BREAK RM., REST RM., = V.C.T. FLOORING
- H) METAL STANDING SEAM GREEN ROOF, INSULATED
- I) A/C TO BE INSTALLED IN OFFICE, BREAKROOM, CARPENTER SHOP, REST ROOMS, MECHANICAL ROOMS
- J) FIRST FOUR FEET OF BUILDING WALLS TO BE SPLIT FACED BLOCK.

- K) ALL BUILD-OUT ROOMS TO HAVE A MINIMUM OF 4 ELECTRICAL OUTLETS.
- L) FIRE RISER & FIRE ALARM PANEL TO BE PLACED IN MECHANICAL ROOM
- M) MAIN BURGLAR PANEL TO BE PLACED IN MECHANICAL ROOM, AND ABOVE THE FLOOR RATED CEILING
- N) A/C DUCT TO BE LOCATED IN BETWEEN THE RATED FLOOR AND ABOVE THE FLOOR RATED CEILING
- O) RESTROOMS TO HAVE CERAMIC TILE FLOORS
- P) KEY-BOX TO BE LOCATED AT THE ENTRY DOOR AND CONNECTED TO THE FIRE PANEL.
- Q) THERMOSTAT TO BE LOCATED IN MAIN OFFICE. REMOVE SENSORS AS DESIGNATED. THERMOSTAT TO HAVE SYSTEM SWITCH WHICH INCLUDES AUTO SETTING.
- R) TELEPHONE AND COMPUTER CONDUIT TO TERMINATE IN MECHANICAL ROOM FROM EXTERIOR

ELECTRICAL NOTES

| |
|---|
| 110 WELDER OWN CIRCUIT - 20 AMP DEDICATED CIRCUIT |
| 220 STICK WELDER - 50 AMP DEDICATED CIRCUIT |
| 220 COMPRESSOR - 15 AMP |
| 220 PLASMA CUTTER - 30 AMP |
| 110 DRILL PRESS - 9 AMP |
| 110 CHOP SAW - 13 AMP |
| 110 BENCH GRINDER - 20 AMP |
| 220 TABLE SAW - 10.5 AMP |